



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 260014287

**Project :** PO#126993

20-February-2018

**PVNC Catholic DSB (St Josephs-Douro)**

Attn : Donna Sorrell

**Date Rec. :** 13 February 2018

**LR Report:** CA18335-FEB18

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3,

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:School Fax: 705-652-8247

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L
1: Analysis Start Date		---	---	13-Feb-18	13-Feb-18	16-Feb-18	16-Feb-18	16-Feb-18
2: Analysis Start Time		---	---	17:15	17:15	16:45	16:45	16:45
3: Analysis Completed Date		---	---	15-Feb-18	15-Feb-18	20-Feb-18	20-Feb-18	20-Feb-18
4: Analysis Completed Time		---	---	10:34	10:34	14:53	14:53	14:53
5: MAC		---	---	0	0	1	10	---
7: MDL		---	---	---	---	0.003	0.006	0.006
8: DW DW-Staff Room	13-Feb-18 14:45	4.0	0.15	0	0	---	---	---
9: RW RW-Utility Room	13-Feb-18 15:00	4.0	---	24	0	---	---	---
10: TW TW-Utility Room	13-Feb-18 15:00	4.0	---	---	---	0.003 <MDL	4.80	4.80

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Nitrate (as N)	Nitrate by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury  
Project Specialist  
Environmental Services, Analytical