



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014261

Project : PO#126993

20-February-2018

PVNC Catholic DSB (Monsgr L Cleary-Courtice)

Attn : Donna Sorrell

Date Rec. : 12 February 2018

LR Report: CA18155-FEB18

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3,

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:School Fax: 905-433-9933

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L
1: Analysis Start Date		---	---	12-Feb-18	12-Feb-18	15-Feb-18	15-Feb-18	15-Feb-18
2: Analysis Start Time		---	---	17:05	17:05	17:05	17:05	17:05
3: Analysis Completed Date		---	---	15-Feb-18	15-Feb-18	20-Feb-18	20-Feb-18	20-Feb-18
4: Analysis Completed Time		---	---	09:16	09:16	10:16	10:16	10:16
5: MAC		---	---	0	0	1	10	---
7: MDL		---	---	---	---	0.003	0.006	0.006
8: DW DW-Rm 154	12-Feb-18 09:30	6.0	0.61	0	0	---	---	---
9: RW RW-Utility Room	12-Feb-18 09:20	6.0	---	0	0	---	---	---
10: TW TW-Utility Room	12-Feb-18 09:35	6.0	---	---	---	0.003 <MDL	0.728	0.728

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Nitrate (as N)	Nitrate by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical