



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014261

Project : PO#126993

23-November-2017

PVNC Catholic DSB (Monsgr L Cleary-Courtice)

Attn : Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3,

Date Rec. : 20 November 2017
LR Report: CA14389-NOV17

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:School Fax: 905-433-9933

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	---	22-Nov-17	22-Nov-17	22-Nov-17	20-Nov-17	20-Nov-17
2: Analysis Start Time		---	---	02:17	02:17	02:17	17:10	17:10
3: Analysis Completed Date		---	---	23-Nov-17	23-Nov-17	23-Nov-17	22-Nov-17	22-Nov-17
4: Analysis Completed Time		---	---	16:02	16:02	16:02	11:51	11:51
5: MAC		---	---	1	10	---	0	0
6: MDL		---	---	0.003	0.006	0.006	---	---
7: DW DW-Room 154	20-Nov-17 08:45	14.0	0.11	---	---	---	0	0
8: RW RW-Utility Room	20-Nov-17 09:00	14.0	---	---	---	---	0	0
9: TW TW-Utility Room	20-Nov-17 09:05	14.0	---	0.003 <MDL	0.673	0.673	---	---

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Nitrate (as N)	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrite by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical