



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014300

Project : PO#126993

24-November-2017

PVNC Catholic DSB (St Lukes-Downeyville)

Attn : Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3,

Date Rec. : 22 November 2017

LR Report: CA17529-NOV17

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:School Fax: 705-799-0583

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	22-Nov-17	22-Nov-17	22-Nov-17	22-Nov-17	22-Nov-17
2: Analysis Start Time		---	20:15	20:15	20:15	16:00	16:00
3: Analysis Completed Date		---	23-Nov-17	23-Nov-17	23-Nov-17	24-Nov-17	24-Nov-17
4: Analysis Completed Time		---	15:44	15:44	15:44	09:29	09:29
5: MAC		---	1	10	---	0	0
6: MDL		---	0.003	0.006	0.006	---	---
7: DW DW-Kindergarten Room	22-Nov-17 07:30	7.0	---	---	---	0	0
8: RW RW-Utility Room	22-Nov-17 07:40	7.0	---	---	---	0	0
9: TW TW-Utility Room	22-Nov-17 07:45	7.0	0.022	3.12	3.14	---	---

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Nitrate (as N)	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical