



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014287
Project : PO#126993

01-September-2017

PVNC Catholic DSB (St Josephs-Douro)
Attn : Donna Sorrell

Date Rec. : 30 August 2017
LR Report: CA14822-AUG17

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3,

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:School Fax: 705-652-8247

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		---	---	30-Aug-17	30-Aug-17	30-Aug-17	30-Aug-17	30-Aug-17
2: Analysis Start Time		---	---	23:26	23:26	23:26	14:40	14:40
3: Analysis Completed Date		---	---	31-Aug-17	31-Aug-17	31-Aug-17	31-Aug-17	31-Aug-17
4: Analysis Completed Time		---	---	11:46	11:46	11:46	16:01	16:01
5: MAC		---	---	1	10	---	0	0
6: MDL		---	---	0.003	0.006	0.006	---	---
7: DW DW-Staff Room	30-Aug-17 11:20	18.0	0.84	---	---	---	0	0
8: RW RW-Utility Room	30-Aug-17 11:30	18.0	---	---	---	---	45	0
9: TW TW-Utility Room	30-Aug-17 11:35	18.0	---	0.003 <MDL	2.24	2.24	---	---

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
NO2	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
NO2+NO3	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
NO3	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical