



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014261

Project : PO#126993

18-August-2017

**PVNC Catholic DSB (Monsgr L Cleary-Courtice)**

Attn : Donna Sorrell

Date Rec. : 15 August 2017

LR Report: CA17905-AUG17

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3,

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:School Fax: 905-433-9933

## CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date		--	--	16-Aug-17	16-Aug-17	16-Aug-17	15-Aug-17	15-Aug-17
2: Analysis Start Time		--	--	22:21	22:21	22:21	18:35	18:35
3: Analysis Completed Date		--	--	18-Aug-17	18-Aug-17	18-Aug-17	17-Aug-17	17-Aug-17
4: Analysis Completed Time		--	--	10:35	10:35	10:35	09:26	09:26
5: MAC		--	--	1	10	--	0	0
6: MDL		--	--	0.003	0.006	0.006	--	--
7: DW DW-Room 154	15-Aug-17 08:00	7.0	0.03	--	--	--	0	0
8: RW RW-Utility Room	15-Aug-17 08:10	7.0	--	--	--	--	0	0
9: TW TW-Utility Room	15-Aug-17 08:15	7.0	--	0.003 <MDL	0.911	0.911	--	--

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
mg/L	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
mg/L	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
mg/L	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical