



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014300

Project : PO#126993

30-August-2017

PVNC Catholic DSB (St Lukes-Downeyville)

Attn : Donna Sorrell

Date Rec. : 29 August 2017

LR Report: CA14791-AUG17

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3,

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:School Fax: 705-799-0583

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Nitrite (as N) mg/L	Nitrate (as N) mg/L	Nitrate + Nitrite (as N) mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date	---	---	29-Aug-17	29-Aug-17	29-Aug-17	29-Aug-17	29-Aug-17
2: Analysis Start Time	---	---	20:01	20:01	20:01	15:45	15:45
3: Analysis Completed Date	---	---	30-Aug-17	30-Aug-17	30-Aug-17	30-Aug-17	30-Aug-17
4: Analysis Completed Time	---	---	12:59	12:59	12:59	16:14	16:14
5: MAC	---	---	1	10	---	0	0
6: MDL	---	---	0.003	0.006	0.006	---	---
7: DW DW-Kindergarten Room	29-Aug-17 08:15	22.0	---	---	---	0	0
8: RW RW-Utility Room	29-Aug-17 08:25	22.0	---	---	---	0	0
9: TW TW-Utility Room	29-Aug-17 08:30	22.0	0.047	3.04	3.09	---	---

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
NO2	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
NO2+NO3	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
NO3	Nitrate by Dionex - solution	ME-CA-[ENV]IC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
Project Specialist
Environmental Services, Analytical