



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038637

**Project :** PO#126993

15-August-2022

**PVNC Catholic DSB (Reg243 - Holy Cross SS)**

Attn : Donna Sorrell

**Date Rec. :** 10 August 2022

**LR Report:** CA16795-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS


## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	15-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		---	15-Aug-22
4: Analysis Completed Time		---	11:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 251-FT-004	10-Aug-22 06:40	23.0	1.10
8: TAP Flushed - 251-FT-004	10-Aug-22 07:15	23.0	0.37
9: TAP Standing - 251-FT-001	10-Aug-22 06:00	23.0	0.43
10: TAP Flushed - 251-FT-001	10-Aug-22 06:35	23.0	0.20
11: TAP Standing - 251-FT-002	10-Aug-22 07:20	23.0	0.40
12: TAP Flushed - 251-FT-002	10-Aug-22 08:00	23.0	0.36

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



Carrie Greenlaw  
Project Specialist,  
Environment, Health & Safety