



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038637

Project : PO#126993

14-September-2021

PVNC Catholic DSB (Reg243 - Holy Cross SS)

Attn : Donna Sorrell

Date Rec. : 08 September 2021

LR Report: CA15183-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	13-Sep-21
2: Analysis Start Time		---	08:05
3: Analysis Completed Date		--	14-Sep-21
4: Analysis Completed Time		--	11:01
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - Drink Fountain Outside Board Office Door	02-Sep-21 07:25	12.0	0.61
8: TAP Flushed - Drink Fountain Outside Board Office Door	02-Sep-21 08:00	12.0	0.20
9: TAP Standing - Beside Mechanical Rm 235	02-Sep-21 07:30	12.0	0.60
10: TAP Flushed - Beside Mechanical Rm 235	02-Sep-21 08:05	12.0	0.27

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety