



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038689

Project : PO#126993

08-August-2022

PVNC Catholic DSB (Reg243 - Holy Family ES)

Attn : Donna Sorrell

Date Rec. : 02 August 2022

LR Report: CA16001-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	05-Aug-22
2: Analysis Start Time		---	16:00
3: Analysis Completed Date		---	08-Aug-22
4: Analysis Completed Time		---	10:47
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 137-FT-004	29-Jul-22 06:00	23.0	1.05
8: TAP Flushed - 137-FT-004	29-Jul-22 06:35	23.0	0.34
9: TAP Standing - 137-FT-003	29-Jul-22 06:10	23.0	0.27
10: TAP Flushed - 137-FT-003	29-Jul-22 06:45	23.0	0.10
11: TAP Standing - 137-FT-001	29-Jul-22 06:15	23.0	0.65
12: TAP Flushed - 137-FT-001	29-Jul-22 06:50	23.0	0.09
13: TAP Standing - 137-FT-005	29-Jul-22 06:25	23.0	0.21
14: TAP Flushed - 137-FT-005	29-Jul-22 07:00	23.0	0.10
15: TAP Standing - 137-FT-006	29-Jul-22 06:35	23.0	0.47
16: TAP Flushed - 137-FT-006	29-Jul-22 07:05	23.0	0.18

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety