



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500156066

**Project :** PO#126993

08-August-2022

**PVNC Catholic DSB (Reg243 - Holy Family ES-Daycare)**

Attn : Donna Sorrell

**Date Rec. :** 02 August 2022

**LR Report:** CA16002-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	05-Aug-22
2: Analysis Start Time		---	16:00
3: Analysis Completed Date		---	08-Aug-22
4: Analysis Completed Time		---	10:47
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing -137-SK-003	29-Jul-22 05:55	23.0	0.30
8: TAP Flushed -137-SK-003	29-Jul-22 06:00	23.0	0.33

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety