



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038715

Project : PO#126993

07-October-2021

PVNC Catholic DSB (Reg243 - Holy Trinity)

Attn : Donna Sorrell

Date Rec. : 01 October 2021

LR Report: CA14008-OCT21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	07-Oct-21
2: Analysis Start Time		---	06:00
3: Analysis Completed Date		---	07-Oct-21
4: Analysis Completed Time		---	13:17
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Closest to Rm 117	29-Sep-21 06:50	20.0	0.94
8: TAP Flushed - Closest to Rm 117	29-Sep-21 07:30	20.0	0.28
9: TAP Standing - Across from Rm 118	29-Sep-21 07:00	20.0	0.18
10: TAP Flushed - Across from Rm 118	29-Sep-21 07:35	20.0	0.07
11: TAP Standing - Closest to Rm 138	29-Sep-21 07:25	20.0	0.07
12: TAP Flushed - Closest to Rm 138	29-Sep-21 08:00	20.0	0.05
13: TAP Standing - Across from Rm 213	30-Sep-21 07:25	20.0	0.21
14: TAP Flushed - Across from Rm 213	30-Sep-21 08:00	20.0	0.18

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety