

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500002900**Project :** PO#126993

11-August-2022

**PVNC Catholic DSB (Reg243 - IM Conception School)**

Attn : Donna Sorrell

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Date Rec. :** 08 August 2022**LR Report:** CA16487-AUG22**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	11-Aug-22
2: Analysis Start Time		---	08:00
3: Analysis Completed Date		--	11-Aug-22
4: Analysis Completed Time		--	14:01
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 106-FT-001	04-Aug-22 11:00	25.0	2.32
8: TAP Flushed - 106-FT-001	04-Aug-22 10:30	25.0	0.36
9: TAP Standing - 106-FT-002	04-Aug-22 12:45	25.0	0.31
10: TAP Flushed - 106-FT-002	04-Aug-22 13:15	25.0	0.27

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety