



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038741

**Project :** PO#126993

11-August-2022

**PVNC Catholic DSB (Reg243 - Msgr L Cleary ES)**

Attn : Donna Sorrell

**Date Rec. :** 08 August 2022

**LR Report:** CA17704-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

| Sample ID                     | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date        |                    | ---                         | 11-Aug-22 |
| 2: Analysis Start Time        |                    | ---                         | 08:00     |
| 3: Analysis Completed Date    |                    | ---                         | 11-Aug-22 |
| 4: Analysis Completed Time    |                    | ---                         | 14:03     |
| 5: MAC                        |                    | ---                         | 10        |
| 6: MDL                        |                    | ---                         | 0.01      |
| 7: TAP Standing - 127-FT-001  | 02-Aug-22 06:05    | 23.0                        | 0.25      |
| 8: TAP Flushed - 127-FT-001   | 02-Aug-22 06:35    | 23.0                        | 0.01 <MDL |
| 9: TAP Standing - 127-FT-002  | 03-Aug-22 06:05    | 23.0                        | 0.01 <MDL |
| 10: TAP Flushed - 127-FT-002  | 03-Aug-22 06:35    | 23.0                        | 0.01 <MDL |
| 11: TAP Standing - 127-FT-003 | 04-Aug-22 06:05    | 23.0                        | 0.01 <MDL |
| 12: TAP Flushed - 127-FT-003  | 04-Aug-22 06:35    | 23.0                        | 0.01 <MDL |

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

| Parameter | Description                   | SGS Method Code           |
|-----------|-------------------------------|---------------------------|
| Lead      | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety