



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500035868

**Project :** PO#126993

27-August-2021

**PVNC Catholic DSB (Reg243 - Msgr O'Donoghue ES)**

Attn : Donna Sorrell

**Date Rec. :** 23 August 2021

**LR Report:** CA18895-AUG21

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	27-Aug-21
2: Analysis Start Time		---	08:06
3: Analysis Completed Date		---	27-Aug-21
4: Analysis Completed Time		---	10:16
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 1st Floor Bottle	20-Aug-21 06:05	23.0	0.37
8: TAP Flushed - 1st Floor Bottle	20-Aug-21 06:40	23.0	0.07
9: TAP Standing - 2nd Floor Bottle	20-Aug-21 06:12	23.0	0.21
10: TAP Flushed - 2nd Floor Bottle	20-Aug-21 06:47	23.0	0.06

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety