



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038780

**Project :** PO#126993

08-September-2021

**PVNC Catholic DSB (Reg243 - Notre Dame ES)**

Attn : Donna Sorrell

**Date Rec. :** 03 September 2021

**LR Report:** CA17711-SEP21

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

| Sample ID                                 | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|---|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date                    |                    | ---                         | 07-Sep-21 |
| 2: Analysis Start Time                    |                    | ---                         | 08:27     |
| 3: Analysis Completed Date                |                    | ---                         | 07-Sep-21 |
| 4: Analysis Completed Time                |                    | ---                         | 14:17     |
| 5: MAC                                    |                    | ---                         | 10        |
| 6: MDL                                    |                    | ---                         | 0.01      |
| 7: TAP Standing - Portable                | 02-Sep-21 07:00    | 27.0                        | 4.25      |
| 8: TAP Flushed - Portable                 | 02-Sep-21 07:35    | 27.0                        | 1.80      |
| 9: TAP Standing - Outside Rm 122          | 02-Sep-21 07:10    | 27.0                        | 0.04      |
| 10: TAP Flushed - Outside Rm 122          | 02-Sep-21 07:45    | 27.0                        | 0.09      |
| 11: TAP Standing - Outside Rm 121         | 02-Sep-21 07:10    | 27.0                        | 0.02      |
| 12: TAP Flushed - Outside Rm 121          | 02-Sep-21 07:45    | 27.0                        | 0.02      |
| 13: TAP Standing - Outside Staff Washroom | 02-Sep-21 07:20    | 27.0                        | 0.21      |
| 14: TAP Flushed - Outside Staff Washroom  | 02-Sep-21 07:55    | 27.0                        | 0.02      |
| 15: TAP Standing - Outside Rm 107         | 02-Sep-21 07:25    | 27.0                        | 0.06      |
| 16: TAP Flushed - Outside Rm 107          | 02-Sep-21 08:00    | 27.0                        | 0.06      |
| 17: TAP Standing - Outside Rm 109         | 02-Sep-21 07:30    | 27.0                        | 0.03      |
| 18: TAP Flushed - Outside Rm 109          | 02-Sep-21 08:05    | 27.0                        | 0.02      |

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

| Parameter | Description                   | SGS Method Code           |
|-----------|-------------------------------|---------------------------|
| Lead      | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038780

**Project :** PO#126993

**LR Report :** CA17711-SEP21

---

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety