



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500035907

Project : PO#126993

02-August-2022

PVNC Catholic DSB (Reg243 - St Alphonsus ES)

Attn : Donna Sorrell

Date Rec. : 26 July 2022

LR Report: CA17077-JUL22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	29-Jul-22
2: Analysis Start Time		---	08:50
3: Analysis Completed Date		---	02-Aug-22
4: Analysis Completed Time		---	09:00
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 108-FT-003	26-Jul-22 06:30	25.0	0.12
8: TAP Flushed - 108-FT-003	26-Jul-22 07:05	25.0	0.08
9: TAP Standing - 108-FT-001	26-Jul-22 06:35	25.0	0.15
10: TAP Flushed - 108-FT-001	26-Jul-22 07:05	25.0	0.23
11: TAP Standing - 108-SK-001	26-Jul-22 06:40	25.0	10.4 MAC
12: TAP Flushed - 108-SK-001	26-Jul-22 07:10	25.0	6.82

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety