



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500035907  
**Project :** PO#126993

13-August-2021

**PVNC Catholic DSB (Reg243 - St Alphonsus ES)**

Attn : Donna Sorrell

**Date Rec. :** 09 August 2021  
**LR Report:** CA17979-AUG21

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

| Sample ID                     | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date        |                    | ---                         | 13-Aug-21 |
| 2: Analysis Start Time        |                    | ---                         | 07:03     |
| 3: Analysis Completed Date    |                    | ---                         | 13-Aug-21 |
| 4: Analysis Completed Time    |                    | ---                         | 10:32     |
| 5: MAC                        |                    | ---                         | 10        |
| 6: MDL                        |                    | ---                         | 0.01      |
| 7: TAP Standing - 108-FT-003  | 09-Aug-21 05:35    | 24.0                        | 0.09 RVNS |
| 8: TAP Flushed - 108 FT-003   | 09-Aug-21 06:10    | 24.0                        | 0.04 RVNS |
| 9: TAP Standing - 108 FT-004  | 05-Aug-21 05:35    | 24.0                        | 0.04 RVNS |
| 10: TAP Flushed - 108 FT-004  | 05-Aug-21 06:10    | 24.0                        | 0.02 RVNS |
| 11: TAP Standing - 108 FT-005 | 04-Aug-21 05:35    | 24.0                        | 0.11 RVNS |
| 12: TAP Flushed - 108 FT-005  | 04-Aug-21 06:10    | 24.0                        | 0.03 RVNS |

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit  
RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

### Method Descriptions

| Parameter | Description                   | SGS Method Code           |
|-----------|-------------------------------|---------------------------|
| Lead      | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety