



**SGS Canada Inc.**  
P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500002835  
**Project :** PO#126993

10-August-2021

**PVNC Catholic DSB (Reg243 - St Anne's ES)**

Attn : Donna Sorrell

**Date Rec. :** 04 August 2021  
**LR Report:** CA16032-AUG21

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	10-Aug-21
2: Analysis Start Time		---	07:08
3: Analysis Completed Date		--	10-Aug-21
4: Analysis Completed Time		--	09:45
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - Near Staff Room (#12)	26-Jul-21 06:00	23.0	2.96 RVNS
8: TAP Flushed - Near Staff Room (#12)	26-Jul-21 06:35	23.0	7.88 RVNS
9: TAP Standing - Near Staff Room (#13)	26-Jul-21 06:00	23.0	3.46 RVNS
10: TAP Flushed - Near Staff Room (#13)	26-Jul-21 06:35	23.0	5.37 RVNS
11: TAP Standing - Beside Room 215 (#15)	27-Jul-21 06:00	23.0	2.39 RVNS
12: TAP Flushed - Beside Room 215 (#15)	27-Jul-21 06:35	23.0	3.47 RVNS
13: TAP Standing - Beside Room 225 (#16)	28-Jul-21 06:00	23.0	2.91 RVNS
14: TAP Flushed - Beside Room 225 (#16)	28-Jul-21 06:35	23.0	2.04 RVNS
15: TAP Standing - Beside Boys Bathroom (#1)	29-Jul-21 06:00	23.0	0.59 RVNS
16: TAP Flushed - Beside Boys Bathroom (#1)	29-Jul-21 06:35	23.0	0.37 RVNS
17: TAP Standing - Beside Boys Bathroom (#2)	29-Jul-21 06:00	23.0	1.48 RVNS
18: TAP Flushed - Beside Boys Bathroom (#2)	29-Jul-21 06:35	23.0	1.07 RVNS
19: TAP Standing - Outside Kitchen (#7)	03-Aug-21 07:00	23.0	20.5 MAC RVNS
20: TAP Flushed - Outside Kitchen (#7)	03-Aug-21 07:35	23.0	21.4 MAC RVNS
21: TAP Standing - Outside Gym (#4/5)	04-Aug-21 07:00	23.0	3.35 RVNS
22: TAP Flushed - Outside Gym (#4/5)	04-Aug-21 07:35	23.0	2.98 RVNS

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit  
RVNS - Required Volume Not Submitted for Lead under 0.Reg243/07.

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500002835

**Project :** PO#126993

**LR Report :** CA16032-AUG21

---

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety