



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038884

Project : PO#126993

02-September-2022

PVNC Catholic DSB (Reg243 - St Anthony's ES)

Attn : Donna Sorrell

Date Rec. : 30 August 2022

LR Report: CA18928-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Sep-22
2: Analysis Start Time		---	08:46
3: Analysis Completed Date		---	02-Sep-22
4: Analysis Completed Time		---	11:29
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 126-FT-001	30-Aug-22 06:30	16.0	3.16
8: TAP Flushed - 126-FT-001	30-Aug-22 07:05	16.0	2.04
9: TAP Standing - 126-FT-003	30-Aug-22 06:30	16.0	0.71
10: TAP Flushed - 126-FT-003	30-Aug-22 07:05	16.0	0.91
11: TAP Standing - 126-FT-005	30-Aug-22 06:40	16.0	0.96
12: TAP Flushed - 126-FT-005	30-Aug-22 07:15	16.0	1.00
13: TAP Standing - 126-FT-006	30-Aug-22 06:40	16.0	1.87
14: TAP Flushed - 126-FT-006	30-Aug-22 07:15	16.0	0.88
15: TAP Standing - 126-FT-008	30-Aug-22 06:45	16.0	0.52
16: TAP Flushed - 126-FT-008	30-Aug-22 07:25	16.0	0.19

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety