



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038884

Project : PO#126993

29-October-2021

PVNC Catholic DSB (Reg243 - St Anthony's ES)

Attn : Donna Sorrell

Date Rec. : 21 October 2021

LR Report: CA18819-OCT21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	28-Oct-21
2: Analysis Start Time		---	07:53
3: Analysis Completed Date		--	28-Oct-21
4: Analysis Completed Time		--	12:02
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - FT 008	21-Oct-21 06:00	18.0	0.39
8: TAP Flushed - FT 008	21-Oct-21 06:35	18.0	0.32
9: TAP Standing - FT-007	21-Oct-21 06:00	18.0	1.04
10: TAP Flushed - FT-007	21-Oct-21 06:35	18.0	0.40
11: TAP Standing - FT-006	21-Oct-21 06:00	18.0	0.37
12: TAP Flushed - FT-006	21-Oct-21 06:35	18.0	0.31
13: TAP Standing - BF-002	21-Oct-21 06:00	18.0	35.0 MAC
14: TAP Flushed - BF-002	21-Oct-21 06:35	18.0	20.9 MAC
15: TAP Standing - FT-005	21-Oct-21 06:00	18.0	7.82
16: TAP Flushed - FT-005	21-Oct-21 06:35	18.0	1.63
17: TAP Standing - BF-001	21-Oct-21 06:00	18.0	0.47
18: TAP Flushed - BF-001	21-Oct-21 06:35	18.0	1.52
19: TAP Standing - FT-002	21-Oct-21 06:00	18.0	0.36
20: TAP Flushed - FT-002	21-Oct-21 06:35	18.0	0.52
21: TAP Standing - FT-003	21-Oct-21 06:00	18.0	0.43
22: TAP Flushed - FT-003	21-Oct-21 06:35	18.0	1.53

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

MAC - (ADVERSE) Above Maximum Acceptable Concentration

Method Descriptions

Description	SGS Method Code
Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038884

Project : PO#126993

LR Report : CA18819-OCT21

Patti Stark
Project Specialist,
Environment, Health & Safety