

Attn : Donna Sorrell

Peterborough, ON K9J 7M3, Canada

1355 Lansdowne Street West

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO Phone: 705-652-2000 FAX: 705-652-6365 Works #: 500081771 Project : PO#126993

26-August-2022

Date Rec.: 23 August 2022 LR Report: CA17224-AUG22

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912 Fax:

PVNC Catholic DSB (Reg243 - St Catherine's ES-Daycare)

## CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			26-Aug-22
2: Analysis Start Time			07:01
3: Analysis Completed Date			26-Aug-22
4: Analysis Completed Time			15:15
5: MAC			10
6: MDL			0.01
7: TAP Standing - 103-FT-007	23-Aug-22 06:10	20.0	1.02
8: TAP Flushed - 103-FT-007	23-Aug-22 06:45	20.0	0.64
9: TAP Standing - 103-SK-003	23-Aug-22 06:10	20.0	0.37
10: TAP Flushed - 103-SK-003	23-Aug-22 06:45	20.0	0.46

MAC - Maximum Acceptable Concentration MDL - SGS Method Detection Limit

	Method	Descri	pti	ons
--	--------	--------	-----	-----

	•		
Parameter	Description	SGS Method Code	
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006	
	g		

Kimberley Didsbury Project Specialist, Environment, Health & Safety

0003027258

Page 1 of 1 Results relate only to the sample tested. Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at https://www.sgs.ca/en/terms-and-conditions (Printed copies are available upon request.) Test method information available upon request. "Temperature Upon Receipt" is representative of the whole shipment and may not reflect the temperature of individual samples. SGS Canada Inc. Environment-Health & Safety statement of conformity decision rule does not consider uncertainty when analytical results are compared to a specified standard or