



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500000885

Project : PO#126993

04-August-2021

PVNC Catholic DSB (Reg243 - St Catherine's ES)

Attn : Donna Sorrell

Date Rec. : 28 July 2021

LR Report: CA18949-JUL21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	04-Aug-21
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		--	04-Aug-21
4: Analysis Completed Time		--	12:39
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 103-FT-004	27-Jul-21 06:00	13.0	0.37
8: TAP Flushed - 103-FT-004	27-Jul-21 06:35	13.0	0.60
9: TAP Standing - 103-FT-006	27-Jul-21 06:00	13.0	0.77
10: TAP Flushed - 103-FT-006	27-Jul-21 06:35	13.0	0.43
11: TAP Standing - 103-BF-003	28-Jul-21 06:00	13.0	0.77
12: TAP Flushed - 103-BF-003	28-Jul-21 06:35	13.0	0.62
13: TAP Standing - 103-FT-003	28-Jul-21 06:00	13.0	0.34
14: TAP Flushed - 103-FT-003	28-Jul-21 06:35	13.0	0.24
15: TAP Standing - 103-BF-002	28-Jul-21 06:00	13.0	0.88
16: TAP Flushed - 103-BF-002	28-Jul-21 06:35	13.0	0.53

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety