



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038858

Project : PO#126993

22-August-2022

PVNC Catholic DSB (Reg243 - St Dominic ES)

Attn : Donna Sorrell

Date Rec. : 16 August 2022

LR Report: CA18190-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	20-Aug-22
2: Analysis Start Time		---	11:01
3: Analysis Completed Date		---	22-Aug-22
4: Analysis Completed Time		---	09:48
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 122-FT-003	12-Aug-22 06:03	16.0	0.87
8: TAP Flushed - 122-FT-003	12-Aug-22 06:38	16.0	0.30
9: TAP Standing - 122-FT-001	12-Aug-22 06:00	16.0	0.53
10: TAP Flushed - 122-FT-001	12-Aug-22 06:35	16.0	0.19
11: TAP Standing - 122-FT-004	12-Aug-22 06:08	16.0	0.24
12: TAP Flushed - 122-FT-004	12-Aug-22 06:43	16.0	0.16

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety