



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038858

Project : PO#126993

16-September-2021

PVNC Catholic DSB (Reg243 - St Dominic ES)

Attn : Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Date Rec. : 08 September 2021

LR Report: CA15185-SEP21

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	16-Sep-21
2: Analysis Start Time		---	10:00
3: Analysis Completed Date		--	16-Sep-21
4: Analysis Completed Time		--	11:20
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 122-FT-001	03-Sep-21 06:03	19.0	0.50
8: TAP Flushed - 122-FT-001	03-Sep-21 06:38	19.0	0.23
9: TAP Standing - #5	03-Sep-21 06:04	19.0	0.84
10: TAP Flushed - #5	03-Sep-21 06:39	19.0	0.34
11: TAP Standing - #11	03-Sep-21 06:05	19.0	0.63
12: TAP Flushed - #11	03-Sep-21 06:40	19.0	0.53

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety