



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038624

**Project :** PO#126993

11-August-2022

**PVNC Catholic DSB (Reg243 - St John's ES Peterborough)**

Attn : Donna Sorrell

**Date Rec. :** 08 August 2022

**LR Report:** CA17707-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	11-Aug-22
2: Analysis Start Time		---	08:00
3: Analysis Completed Date		---	11-Aug-22
4: Analysis Completed Time		---	13:59
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 110-FT-001	28-Jul-22 06:30	23.0	1.19
8: TAP Flushed - 110-FT-001	28-Jul-22 07:10	23.0	0.36
9: TAP Standing - 110-FT-004	29-Jul-22 06:30	23.0	5.59
10: TAP Flushed - 110-FT-004	29-Jul-22 07:10	23.0	3.57
11: TAP Standing - 110-SK-005	02-Aug-22 06:30	23.0	1.97
12: TAP Flushed - 110-SK-005	02-Aug-22 07:15	23.0	0.32
13: TAP Standing - 110-FT-017	04-Aug-22 06:40	23.0	0.83
14: TAP Flushed - 110-FT-017	04-Aug-22 07:20	23.0	0.72
15: TAP Standing - 110-FT-007	03-Aug-22 06:37	23.0	10.7 MAC
16: TAP Flushed - 110-FT-007	03-Aug-22 07:39	23.0	1.55
17: TAP Standing - 110-SK-004	05-Aug-22 06:30	23.0	1.58
18: TAP Flushed - 110-SK-004	05-Aug-22 07:10	23.0	1.12

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038624

**Project :** PO#126993

**LR Report :** CA17707-AUG22

---

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety