



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002848

Project : PO#126993

11-August-2022

PVNC Catholic DSB (Reg243 - Pope John Paul II ES)

Attn : Donna Sorrell

Date Rec. : 08 August 2022

LR Report: CA16485-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	11-Aug-22
2: Analysis Start Time		---	08:00
3: Analysis Completed Date		--	11-Aug-22
4: Analysis Completed Time		--	14:01
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 115-FT-001	04-Aug-22 06:10	25.0	6.96
8: TAP Flushed - 115-FT-001	04-Aug-22 06:45	25.0	3.31
9: TAP Standing - 115-FT-003	04-Aug-22 06:15	25.0	6.91
10: TAP Flushed - 115-FT-003	04-Aug-22 06:50	25.0	5.34

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety