



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038624

Project : PO#126993

20-September-2021

PVNC Catholic DSB (Reg243 - St John's ES Peterborough)

Attn : Donna Sorrell

Date Rec. : 15 September 2021

LR Report: CA18187-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	20-Sep-21
2: Analysis Start Time		---	07:30
3: Analysis Completed Date		---	20-Sep-21
4: Analysis Completed Time		---	11:42
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 5th Floor Fountain	14-Sep-21 07:55	23.0	2.08
8: TAP Flushed - 5th Floor Fountain	14-Sep-21 08:30	23.0	1.03
9: TAP Standing - 4th Floor Fountain	14-Sep-21 08:03	23.0	6.02
10: TAP Flushed - 4th Floor Fountain	14-Sep-21 08:38	23.0	2.21
11: TAP Standing - 3rd Floor Fountain	15-Sep-21 07:21	23.0	8.70
12: TAP Flushed - 3rd Floor Fountain	15-Sep-21 07:56	23.0	2.84
13: TAP Standing - 2nd Floor Fountain	14-Sep-21 07:43	23.0	3.89
14: TAP Flushed - 2nd Floor Fountain	14-Sep-21 08:18	23.0	1.96
15: TAP Standing - Entrance Hall	14-Sep-21 07:33	23.0	1.33
16: TAP Flushed - Entrance Hall	14-Sep-21 08:08	23.0	0.78
17: TAP Standing - Basement F	14-Sep-21 08:12	23.0	9.31
18: TAP Flushed - Basement F	14-Sep-21 08:47	23.0	3.63

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038624

Project : PO#126993

LR Report : CA18187-SEP21

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety