



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038676

**Project :** PO#126993

25-August-2022

**PVNC Catholic DSB (Reg243 - St Joseph's ES-Bowmanville)**

Attn : Donna Sorrell

**Date Rec. :** 22 August 2022

**LR Report:** CA18301-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	25-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		---	25-Aug-22
4: Analysis Completed Time		---	10:08
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 119-FT-003	18-Aug-22 06:04	22.0	0.62
8: TAP Flushed - 119-FT-003	18-Aug-22 06:39	22.0	0.71
9: TAP Standing - 119-FT-006	17-Aug-22 06:02	22.0	3.24
10: TAP Flushed - 119-FT-006	17-Aug-22 06:37	22.0	1.21
11: TAP Standing - 119-FT-004	16-Aug-22 06:04	22.0	1.27
12: TAP Flushed - 119-FT-004	16-Aug-22 06:40	22.0	0.79

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety