

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038767**Project :** PO#126993

22-August-2022

PVNC Catholic DSB (Reg243 - St Joseph's ES-Cobourg)

Attn : Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Date Rec. : 18 August 2022**LR Report:** CA17009-AUG22**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	20-Aug-22
2: Analysis Start Time		---	11:01
3: Analysis Completed Date		---	22-Aug-22
4: Analysis Completed Time		---	09:47
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 121-FT-001	17-Aug-22 06:00	22.0	7.22
8: TAP Flushed - 121-FT-001	17-Aug-22 06:35	22.0	4.20 RVNS
9: TAP Standing - 121-FT-003	17-Aug-22 06:00	22.0	1.09
10: TAP Flushed - 121-FT-003	17-Aug-22 06:35	22.0	1.65

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety