



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038767

**Project :** PO#126993

03-September-2021

**PVNC Catholic DSB (Reg243 - St Joseph's ES-Cobourg)**

Attn : Donna Sorrell

**Date Rec. :** 01 September 2021

**LR Report:** CA17577-SEP21

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912  
Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	03-Sep-21
2: Analysis Start Time		---	07:13
3: Analysis Completed Date		--	03-Sep-21
4: Analysis Completed Time		--	09:44
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - BF #2	01-Sep-21 06:27	23.0	4.50
8: TAP Flushed - BF #2	01-Sep-21 07:03	23.0	2.32

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety