

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500107381**Project :** PO#126993

02-August-2022

PVNC Catholic DSB (Reg243 - St Joseph's ES-Douro)**Attn :** Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Date Rec. : 27 July 2022**LR Report:** CA17219-JUL22**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		--	02-Aug-22
4: Analysis Completed Time		--	10:42
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 102-FT-001	27-Jul-22 07:00	26.0	0.15
8: TAP Flushed - 102-FT-001	27-Jul-22 07:30	26.0	0.06
9: TAP Standing - 102-FT-002	27-Jul-22 07:00	26.0	0.04
10: TAP Flushed - 102-FT-002	27-Jul-22 07:30	26.0	0.06

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety