

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500149579**Project :** PO#126993

22-August-2022

PVNC Catholic DSB (Reg243 - St Luke's ES)

Attn : Donna Sorrell

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Date Rec. : 18 August 2022**LR Report:** CA17008-AUG22**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	20-Aug-22
2: Analysis Start Time		---	11:01
3: Analysis Completed Date		---	22-Aug-22
4: Analysis Completed Time		---	09:45
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 130-FT-003	17-Aug-22 06:30	22.0	0.02
8: TAP Flushed - 130-FT-003	17-Aug-22 07:05	22.0	0.01 <MDL
9: TAP Standing - 130-FT-002	17-Aug-22 06:35	22.0	0.12
10: TAP Flushed - 130-FT-002	17-Aug-22 07:10	22.0	0.11

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Angela Stott, B.Sc.

Branch Manager-London

Environment, Health & Safety