

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260014313 Project : PO#126993

21-October-2022

Date Rec.: 18 October 2022 LR Report: CA17090-OCT22

Copy: #1

PVNC Catholic DSB (St Martins-Ennismore)

Attn: Donna Sorrell

1355 Lansdowne Street West

Peterborough, ON K9J 7M3, Canada

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:School Fax: 705-292-1915

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL
1: Analysis Start Date				19-Oct-22	19-Oct-22
2: Analysis Start Time				10:29	10:29
3: Analysis Completed Date				21-Oct-22	21-Oct-22
4: Analysis Completed Time				11:51	11:51
5: MAC				0	0
6: DW DW-Staff Room	18-Oct-22 15:30	12.0	1.82	0	0
7: RW RW-Utility Room	18-Oct-22 15:35	12.0		0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

	<u>'</u>	
Parameter	Description	SGS Method Code
E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-IENI/IMIC-LAK-AN-001

Kimberley Didsbury

Project Specialist,

Environment, Health & Safety