



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002874

Project : PO#126993

16-August-2022

PVNC Catholic DSB (Reg243 - St Mary's ES-Campbellford)

Attn : Donna Sorrell

Date Rec. : 11 August 2022

LR Report: CA17902-AUG22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	15-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		---	15-Aug-22
4: Analysis Completed Time		---	11:33
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 120-FT-001	10-Aug-22 07:15	22.0	13.2 RVNS MAC
8: TAP Flushed - 120-FT-001	10-Aug-22 07:45	22.0	2.63 RVNS
9: TAP Standing - 120-FT-003	11-Aug-22 07:15	22.0	12.6 RVNS MAC
10: TAP Flushed - 120-FT-003	11-Aug-22 07:45	22.0	0.89 RVNS

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit
RVNS - Required Volume Not Submitted for Lead under 0.Reg243/07.
MAC - (ADVERSE) Above Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
ug/L	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006


Carrie Greenlaw
Project Specialist,
Environment, Health & Safety