



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002874

Project : PO#126993

14-September-2021

PVNC Catholic DSB (Reg243 - St Mary's ES-Campbellford)

Attn : Donna Sorrell

Date Rec. : 10 September 2021

LR Report: CA16581-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|------------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date | | --- | 14-Sep-21 |
| 2: Analysis Start Time | | --- | 07:41 |
| 3: Analysis Completed Date | | --- | 14-Sep-21 |
| 4: Analysis Completed Time | | --- | 10:32 |
| 5: MAC | | --- | 10 |
| 6: MDL | | --- | 0.01 |
| 7: TAP Standing - Upper By Rm 303 | 31-Aug-21 08:00 | 21.0 | 19.8 MAC |
| 8: TAP Flushed - Upper By Rm 303 | 31-Aug-21 08:35 | 21.0 | 2.50 |
| 9: TAP Standing - Outside 310 | 03-Sep-21 07:00 | 21.0 | 13 MAC |
| 10: TAP Flushed - Outside 310 | 03-Sep-21 07:35 | 21.0 | 3.29 |
| 11: TAP Standing - By Rm 100 | 02-Sep-21 07:15 | 21.0 | 29.3 MAC |
| 12: TAP Flushed - By Rm 100 | 02-Sep-21 07:50 | 21.0 | 2.52 |
| 13: TAP Standing - Outside 201 | 08-Sep-21 07:00 | 21.0 | 7.29 |
| 14: TAP Flushed - Outside 201 | 08-Sep-21 07:35 | 21.0 | 1.47 |
| 15: TAP Standing - By Kindergarden | 09-Sep-21 07:15 | 21.0 | 3.44 |
| 16: TAP Flushed - By Kindergarden | 09-Sep-21 07:50 | 21.0 | 2.31 |

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

Note:

- Some sample IDs on the Chain of Custody are different than the bottle labels. Used the IDs on the bottle labels as per client.

Method Descriptions

| Parameter | Description | SGS Method Code |
|-----------|-------------------------------|---------------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002874

Project : PO#126993

LR Report : CA16581-SEP21

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety