



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500124190

Project : PO#126993

03-September-2021

PVNC Catholic DSB (Reg243 - St Mary's ES-Grafton)

Attn : Donna Sorrell

Date Rec. : 01 September 2021

LR Report: CA17578-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	03-Sep-21
2: Analysis Start Time		---	07:13
3: Analysis Completed Date		---	03-Sep-21
4: Analysis Completed Time		---	09:44
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 124-FT-003	01-Sep-21 06:51	23.0	1.60
8: TAP Flushed - 124-FT-003	01-Sep-21 07:26	23.0	0.54
9: TAP Standing - 124-FT-002	01-Sep-21 06:52	23.0	2.77 RVNS
10: TAP Flushed - 124-FT-002	01-Sep-21 07:27	23.0	0.50
11: TAP Standing - 124-FT-001	01-Sep-21 06:57	23.0	1.68
12: TAP Flushed - 124-FT-001	01-Sep-21 07:31	23.0	0.36

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety