



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500002887

Project : PO#126993

03-September-2021

PVNC Catholic DSB (Reg243 - St Michael's ES)

Attn : Donna Sorrell

Date Rec. : 01 September 2021

LR Report: CA17576-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	03-Sep-21
2: Analysis Start Time		---	07:13
3: Analysis Completed Date		--	03-Sep-21
4: Analysis Completed Time		--	09:08
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 003	31-Aug-21 06:45	23.0	7.01
8: TAP Flushed - 003	31-Aug-21 07:20	23.0	2.20
9: TAP Standing - 005	31-Aug-21 06:50	23.0	31.9 MAC
10: TAP Flushed - 005	31-Aug-21 07:25	23.0	6.91

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety