



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038702

Project : PO#126993

02-August-2022

PVNC Catholic DSB (Reg243 - Mother Teresa ES)

Attn : Donna Sorrell

Date Rec. : 27 July 2022

LR Report: CA17217-JUL22

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		--	02-Aug-22
4: Analysis Completed Time		--	10:41
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 116-SK-001	27-Jul-22 06:35	26.0	0.21
8: TAP Flushed - 116-SK-001	27-Jul-22 07:10	26.0	0.35
9: TAP Standing - 116-FT-001	27-Jul-22 06:40	26.0	4.10
10: TAP Flushed - 116-FT-001	27-Jul-22 07:15	26.0	2.17
11: TAP Standing - 116-FT-005	27-Jul-22 06:46	26.0	0.07
12: TAP Flushed - 116-FT-005	27-Jul-22 07:21	26.0	0.09
13: TAP Standing - 116-FT-003	27-Jul-22 06:52	26.0	0.21
14: TAP Flushed - 116-FT-003	27-Jul-22 07:27	26.0	0.06
15: TAP Standing - 116-FT-006	27-Jul-22 06:58	26.0	0.08
16: TAP Flushed - 116-FT-006	27-Jul-22 07:33	26.0	0.04

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety