



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038702

Project : PO#126993

13-October-2021

PVNC Catholic DSB (Reg243 - Mother Teresa ES - Day Care)

Attn : Donna Sorrell

Date Rec. : 08 October 2021

LR Report: CA16484-OCT21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-----------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date | | --- | 12-Oct-21 |
| 2: Analysis Start Time | | --- | 13:59 |
| 3: Analysis Completed Date | | -- | 13-Oct-21 |
| 4: Analysis Completed Time | | -- | 11:44 |
| 5: MAC | | -- | 10 |
| 6: MDL | | --- | 0.01 |
| 7: TAP Standing - Daycare Kitchen | 07-Oct-21 06:34 | 22.0 | 0.53 |
| 8: TAP Flushed - Daycare Kitchen | 07-Oct-21 07:09 | 22.0 | 0.59 |

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

| Parameter | Description | SGS Method Code |
|-----------|-------------------------------|---------------------------|
| Lead | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety