



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038702

Project : PO#126993

13-October-2021

PVNC Catholic DSB (Reg243 - Mother Teresa ES)

Attn : Donna Sorrell

Date Rec. : 08 October 2021

LR Report: CA16462-OCT21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	13-Oct-21
2: Analysis Start Time		---	11:21
3: Analysis Completed Date		---	13-Oct-21
4: Analysis Completed Time		---	11:44
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - Outside of Rm #147	05-Oct-21 06:36	22.0	0.15
8: TAP Flushed - Outside of Rm #147	05-Oct-21 07:12	22.0	0.07
9: TAP Standing - Across From Main Office	06-Oct-21 06:41	22.0	0.08
10: TAP Flushed - Across From Main Office	06-Oct-21 07:16	22.0	0.06
11: TAP Standing - Across From Rm #162	06-Oct-21 06:49	22.0	0.48
12: TAP Flushed - Across From Rm #162	06-Oct-21 07:24	22.0	0.10
13: TAP Standing - Outside of Rm #216	07-Oct-21 06:43	22.0	0.15
14: TAP Flushed - Outside of Rm #216	07-Oct-21 07:18	22.0	0.04

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety