

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500081784

Project : PO#126993

11-August-2022

Date Rec.: 08 August 2022 LR Report: CA17708-AUG22

Copy: #1

PVNC Catholic DSB (Reg243 - St Patrick's ES-Daycare)

Attn: Donna Sorrell

1355 Lansdowne Street West Peterborough, ON K9J 7M3, Canada

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date			11-Aug-22
2: Analysis Start Time			08:00
3: Analysis Completed Date			11-Aug-22
4: Analysis Completed Time			14:04
5: MAC			10
6: MDL			0.01
7: TAP Standing - 111-SK-004	05-Aug-22 05:00	23.0	2.53
8: TAP Flushed - 111-SK-004	05-Aug-22 05:35	23.0	1.33
9: TAP Standing - 111-FT-002	05-Aug-22 05:00	23.0	2.69
10: TAP Flushed - 111-FT-002	05-Aug-22 05:35	23.0	0.57

MAC - Maximum Acceptable Concentration MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury, Project Specialist,

Environment, Health & Safety