



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500081784

Project : PO#126993

27-July-2021

PVNC Catholic DSB (Reg243 - St Patrick's ES-Daycare)

Attn : Donna Sorrell

Date Rec. : 22 July 2021

LR Report: CA18636-JUL21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	27-Jul-21
2: Analysis Start Time		---	06:30
3: Analysis Completed Date		---	27-Jul-21
4: Analysis Completed Time		---	13:29
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - BF001	22-Jul-21 05:05	23.0	0.50
8: TAP Flushed - BF001	22-Jul-21 05:45	23.0	0.85

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety