

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038611**Project :** PO#126993

02-August-2022

**PVNC Catholic DSB (Reg243 - St Paul's ES-Peterborough)**

Attn : Donna Sorrell

**Date Rec. :** 28 July 2022**LR Report:** CA17435-JUL22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	02-Aug-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		---	02-Aug-22
4: Analysis Completed Time		---	10:43
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 112-FT-003	20-Jul-22 07:15	23.0	4.23
8: TAP Flushed - 112-FT-003	20-Jul-22 07:45	23.0	4.17
9: TAP Standing - 112-FT-004	20-Jul-22 06:40	23.0	6.50
10: TAP Flushed - 112-FT-004	20-Jul-22 07:10	23.0	3.85
11: TAP Standing - 112-FT-002	26-Jul-22 06:30	23.0	1.39
12: TAP Flushed - 112-FT-002	26-Jul-22 07:05	23.0	0.96
13: TAP Standing - 112-FT-005	26-Jul-22 07:10	23.0	3.29
14: TAP Flushed - 112-FT-005	26-Jul-22 07:45	23.0	1.54

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury  
Project Specialist,  
Environment, Health & Safety