



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038611

Project : PO#126993

17-September-2021

PVNC Catholic DSB (Reg243 - St Paul's ES-Peterborough)

Attn : Donna Sorrell

Date Rec. : 14 September 2021

LR Report: CA17942-SEP21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	17-Sep-21
2: Analysis Start Time		---	09:30
3: Analysis Completed Date		---	17-Sep-21
4: Analysis Completed Time		---	12:04
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - BF-001	09-Sep-21 06:35	18.0	11.0 MAC
8: TAP Flushed - BF-001	09-Sep-21 07:10	18.0	5.59
9: TAP Standing - BF-002	09-Sep-21 06:40	18.0	6.62
10: TAP Flushed - BF-002	09-Sep-21 07:15	18.0	4.24
11: TAP Standing - BF-005	09-Sep-21 06:45	18.0	2.42
12: TAP Flushed - BF-005	09-Sep-21 07:20	18.0	1.24
13: TAP Standing - BF-003	09-Sep-21 06:50	18.0	2.19
14: TAP Flushed - BF-003	09-Sep-21 07:25	18.0	0.84
15: TAP Standing - BF-004	09-Sep-21 06:55	18.0	7.48
16: TAP Flushed - BF-004	09-Sep-21 07:30	18.0	3.23

MAC - Maximum Acceptable Concentration
MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety