



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500035894

**Project :** PO#126993

11-August-2022

**PVNC Catholic DSB (Reg243 - St Peter's SS)**

Attn : Donna Sorrell

**Date Rec. :** 08 August 2022

**LR Report:** CA16486-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	11-Aug-22
2: Analysis Start Time		---	08:00
3: Analysis Completed Date		--	11-Aug-22
4: Analysis Completed Time		--	14:01
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 253-FT-002	03-Aug-22 06:00	24.0	1.65
8: TAP Flushed - 253-FT-002	03-Aug-22 06:35	24.0	0.88
9: TAP Standing - 253-FT-004	02-Aug-22 06:00	24.0	1.12
10: TAP Flushed - 253-FT-004	02-Aug-22 06:35	24.0	0.70
11: TAP Standing - 253-FT-001	05-Aug-22 06:00	24.0	0.30
12: TAP Flushed - 253-FT-001	05-Aug-22 06:35	24.0	0.22
13: TAP Standing - 253-FT-005	04-Aug-22 06:00	24.0	1.39
14: TAP Flushed - 253-FT-005	04-Aug-22 06:35	24.0	2.04

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety