



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500035894
Project : PO#126993

31-August-2021

PVNC Catholic DSB (Reg243 - St Peter's SS)

Attn : Donna Sorrell

Date Rec. : 26 August 2021
LR Report: CA17459-AUG21

1355 Lansdowne Street West
 Peterborough, ON
 K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	31-Aug-21
2: Analysis Start Time		---	07:53
3: Analysis Completed Date		---	31-Aug-21
4: Analysis Completed Time		---	11:19
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - WF Near Gym 1	24-Aug-21 05:55	8.0	2.42
8: TAP Flushed - WF Near Gym 1	24-Aug-21 06:30	8.0	0.70
9: TAP Standing - WF Near Gym 2	24-Aug-21 06:00	8.0	1.25
10: TAP Flushed - WF Near Gym 2	24-Aug-21 06:35	8.0	1.13
11: TAP Standing - WF Near SPED 3	24-Aug-21 06:05	8.0	2.16
12: TAP Flushed - WF Near SPED 3	24-Aug-21 06:40	8.0	1.33
13: TAP Standing - WF Near Science	25-Aug-21 05:55	8.0	0.58
14: TAP Flushed - WF Near Science	25-Aug-21 06:30	8.0	0.32
15: TAP Standing - WF Near 204	25-Aug-21 06:00	8.0	1.47
16: TAP Flushed - WF Near 204	25-Aug-21 06:35	8.0	0.91

MAC - Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



Kimberley Didsbury
 Project Specialist,
 Environment, Health & Safety