



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038728

**Project :** PO#126993

22-August-2022

**PVNC Catholic DSB (Reg243 - St Stephen's SS)**

Attn : Donna Sorrell

**Date Rec. :** 17 August 2022

**LR Report:** CA16943-AUG22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

| Sample ID                     | Sample Date & Time | Temperature Upon Receipt °C | Lead ug/L |
|-------------------------------|--------------------|-----------------------------|-----------|
| 1: Analysis Start Date        |                    | ---                         | 20-Aug-22 |
| 2: Analysis Start Time        |                    | ---                         | 11:01     |
| 3: Analysis Completed Date    |                    | --                          | 22-Aug-22 |
| 4: Analysis Completed Time    |                    | --                          | 09:43     |
| 5: MAC                        |                    | --                          | 10        |
| 6: MDL                        |                    | ---                         | 0.01      |
| 7: TAP Standing - 257-FT-002  | 09-Aug-22 06:12    | 26.0                        | 0.26      |
| 8: TAP Flushed - 257-FT-002   | 09-Aug-22 06:49    | 26.0                        | 0.07      |
| 9: TAP Standing - 257-FT-001  | 11-Aug-22 06:04    | 26.0                        | 0.11      |
| 10: TAP Flushed - 257-FT-001  | 11-Aug-22 06:41    | 26.0                        | 0.04      |
| 11: TAP Standing - 257-FT-003 | 10-Aug-22 06:01    | 26.0                        | 0.27      |
| 12: TAP Flushed - 257-FT-003  | 10-Aug-22 06:37    | 26.0                        | 0.10      |
| 13: TAP Standing - 257-BF-004 | 09-Aug-22 06:12    | 26.0                        | 0.13      |
| 14: TAP Flushed - 257-BF-004  | 09-Aug-22 06:49    | 26.0                        | 0.11      |
| 15: TAP Standing - 257-FT-004 | 09-Aug-22 06:12    | 26.0                        | 0.18      |
| 16: TAP Flushed - 257-FT-004  | 09-Aug-22 06:50    | 26.0                        | 0.11      |
| 17: TAP Standing - 257-FT-009 | 09-Aug-22 06:12    | 26.0                        | 0.21      |
| 18: TAP Flushed - 257-FT-009  | 09-Aug-22 06:50    | 26.0                        | 0.07      |
| 19: TAP Standing - 257-FT-010 | 11-Aug-22 06:12    | 26.0                        | 0.38      |
| 20: TAP Flushed - 257-FT-010  | 11-Aug-22 06:48    | 26.0                        | 0.24      |

MAC - Maximum Acceptable Concentration  
MDL - SGS Method Detection Limit

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500038728

**Project :** PO#126993

**LR Report :** CA16943-AUG22

Method Descriptions

| Parameter | Description                   | SGS Method Code           |
|-----------|-------------------------------|---------------------------|
| Lead      | Lead by ICP-MS Drinking Water | ME-CA-[ENV]SPE-LAK-AN-006 |

---

Angela Stott, B.Sc.  
Branch Manager-London  
Environment, Health & Safety