



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038728

Project : PO#126993

31-August-2021

PVNC Catholic DSB (Reg243 - St Stephen's SS)

Attn : Donna Sorrell

Date Rec. : 26 August 2021

LR Report: CA15581-AUG21

1355 Lansdowne Street West
Peterborough, ON
K9J 7M3, Canada

Copy: #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	30-Aug-21
2: Analysis Start Time		---	10:35
3: Analysis Completed Date		---	31-Aug-21
4: Analysis Completed Time		---	11:13
5: MAC		---	10
6: MDL		---	0.01
7: TAP Standing - 3	23-Aug-21 05:54	24.0	0.67
8: TAP Flushed - 3	23-Aug-21 06:29	24.0	0.18
9: TAP Standing - 9	24-Aug-21 07:20	24.0	0.12
10: TAP Flushed - 9	24-Aug-21 07:55	24.0	0.15
11: TAP Standing - 13	24-Aug-21 07:20	24.0	0.06
12: TAP Flushed - 13	24-Aug-21 07:55	24.0	0.04
13: TAP Standing - 14	24-Aug-21 07:20	24.0	0.93
14: TAP Flushed - 14	24-Aug-21 07:55	24.0	0.26
15: TAP Standing - 15	24-Aug-21 07:20	24.0	1.70 RVNS
16: TAP Flushed - 15	24-Aug-21 07:55	24.0	0.92
17: TAP Standing - 2	25-Aug-21 06:28	24.0	0.25
18: TAP Flushed - 2	25-Aug-21 07:10	24.0	0.11
19: TAP Standing - 7	25-Aug-21 06:28	24.0	0.48
20: TAP Flushed - 7	25-Aug-21 07:10	24.0	0.10
21: TAP Standing - 10	25-Aug-21 06:28	24.0	0.73
22: TAP Flushed - 10	25-Aug-21 07:10	24.0	0.16

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0. Reg243/07.

Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 500038728

Project : PO#126993

LR Report : CA15581-AUG21

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety