



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 500035855

**Project :** PO#126993

25-July-2022

**PVNC Catholic DSB (Reg243 - St Theresa's ES)**

Attn : Donna Sorrell

**Date Rec. :** 21 July 2022

**LR Report:** CA16730-JUL22

1355 Lansdowne Street West  
Peterborough, ON  
K9J 7M3, Canada

**Copy:** #1

Phone: 705-748-4861 ext.286, Cell:905-396-7912

Fax:

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Lead ug/L
1: Analysis Start Date		---	25-Jul-22
2: Analysis Start Time		---	07:00
3: Analysis Completed Date		--	25-Jul-22
4: Analysis Completed Time		--	11:13
5: MAC		--	10
6: MDL		---	0.01
7: TAP Standing - 117-FT-001	20-Jul-22 05:30	24.0	0.56 RVNS
8: TAP Flushed - 117-FT-001	20-Jul-22 06:00	24.0	0.46 RVNS
9: TAP Standing - 117-FT-004	20-Jul-22 05:30	24.0	0.71 RVNS
10: TAP Flushed - 117-FT-004	20-Jul-22 06:00	24.0	0.76 RVNS
11: TAP Standing - 117-SK-003	20-Jul-22 05:30	24.0	1.47
12: TAP Flushed - 117-SK-003	20-Jul-22 06:00	24.0	0.44

MAC - Maximum Acceptable Concentration

MDL - SGS Method Detection Limit

RVNS - Required Volume Not Submitted for Lead under 0.Reg243/07.

### Method Descriptions

Parameter	Description	SGS Method Code
Lead	Lead by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006

**Kimberley Didsbury**  
Project Specialist,  
Environment, Health & Safety